

THE CURB RAMP SHALL:

1. HAVE A RUNNING SLOPE OF 1:10
2. HAVE A WIDTH OF NOT LESS THAN 1.5m EXCLUSIVE OF SIDEWAYS;
3. HAVE A SURFACE INCLUDING FLARED SIDES THAT SHALL :
 - A. BE SLIP-RESISTANT ;
 - B. HAVE A DETECTABLE WARNING SURFACE THAT IS COLOUR- AND TEXTURE-CONTRASTED WITH THE ADJACENT SURFACES; AND
 - C. HAVE A SMOOTH TRANSITION FROM THE RAMP AND ADJACENT SURFACES.
4. HAVE FLARED SIDES WITH A SLOPE OF NOT MORE THAN 1:10 WHERE PEDESTRIANS ARE LIKELY TO WALK ACROSS THEM




Diagram illustrating the planting detail for a shrub, showing the layers and components involved:

- PRUNE DAMAGED BRANCHES
- REMOVE ALL PLASTIC TAGS WRAPPINGS, POTS, ETC.
- PLANT AT SAME GRADE AS GROWN IN NURSERY
- 50MM MULCH LAYER ON BED
- CONTINUOUS PVC BED EDGE
- ROOT CONTAINMENT AS SPEC'D
- SCARIFY BOTTOM OF BED PRIOR TO PLACEMENT OF PLANTING SOIL
- PLANTING SOIL
- 400 MM.

SHRUB PLANTING — DETAIL
SCALE: N.T.S.

NOT AUTHENTIC UNLESS SIGNED AND DATED



LRL
ENGINEERING | INGÉNIERIE

5430 Canotek Road | Ottawa, ON, K1J 9G2
www.lrl.ca | (613) 842-3434

CLIENT

BATHSFIELD INDUSTRIES LIMITED

DESIGNED BY:	DRAWN BY:	APPROVED BY:
K.H.	K.H.	M.B.

PROJECT

**WAREHOUSE DEVELOPMENT
CORDUROY ROAD / SERVICE STREET
VARS, ON**